



## ICC-ES PMG Product Certificate



**PMG-1070**

Effective Date: February 2024

This listing is subject to re-examination in one year.

[www.icc-es-pmg.org](http://www.icc-es-pmg.org) | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

**CSI:** DIVISION: 22 00 00—PLUMBING  
Section: 22 13 16—Sanitary Waste and Vent Piping

### Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

**Product:** SureSeal® - Barrier Type Floor Drain Trap Seal Protection Devices ("Device")

**Listee:** RectorSeal, LLC  
2601 Spenwick Drive  
Houston, Texas 77055  
[www.rectorseal.com](http://www.rectorseal.com)

### Compliance with the following codes:

2024, 2021, 2018, 2015, 2012, 2009 and 2006 *International Plumbing Code*® (IPC)  
2021, 2018, 2015, 2012, 2009 and 2006 *International Residential Code*® (IRC)  
2024, 2021, 2018, 2015, 2012, 2009 and 2006 *National Standard Plumbing Code*® (NSPC)  
2024, 2021, 2018, 2015, 2012, 2009 and 2006 *Uniform Plumbing Code*® (UPC)\*  
\*Copyrighted publication of the International Association of Plumbing and Mechanical Officials

### Compliance with the following standards:

ASSE 1072-2020, Performance Requirements for Barrier Type Floor Drain Trap Seal Protection Devices, American Society of Sanitary Engineering.  
ICC-ES LC1015, PMG Listing Criteria for Elastomeric, Normally Closed, Floor Drain Evaporation Resistant Sealing System (Oct 2010)

### Identification:

The product and/or package must bear the SureSeal® name, the model number and the ICC-ES PMG listing mark.

### Installation:

SureSeal® trap primer alternates are to be installed in accordance with the manufacturer's instructions and the applicable code.

Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.

**Models:**

<b>MODEL</b>	<b>Device SIZE</b>		<b>FLOW RATE</b>	
	<b><u>Inches</u></b>	<b><u>mm DN</u></b>	<b><u>GPM</u></b>	<b><u>L/M</u></b>
SS2009V	2	40	12.0	45.4
SS3009V	3	50	34.0	128.7
SS3509V	3½	80	52.0	196.6
SS4009V	4	100	73.0	276.4
SS2009Plus	2	40	12.0	45.4
SS3009Plus	3	50	34.0	128.7
SS4009Plus	4	100	73.0	276.4

**Conditions of listing:**

1. SureSeal® devices, recognized by this listing, are intended to serve as alternates to the code-required trap primer. They must serve a functioning trap.
2. The plumbing systems must be installed in accordance with the applicable codes.
3. The "Device" must be accessible.
4. SureSeal® trap primer alternates are manufactured under a quality control program with annual surveillance inspections.